



Installation And Safety Instructions

LR-118

Line art shown may not exactly match the fixture enclosed. However, the installation instructions do apply to this fixture. Fill in Item Number on Carton and File This Sheet For Future Reference. ITEM# _____

041409


IMPORTANT SAFETY INSTRUCTIONS

- Be sure the electricity to the system you are working on is turned off; either the fuse removed or the circuit breaker set at off.
- For use with the 120V Transitions track series by Sea Gull Lighting.
- Caution – To reduce the risk of burn during relamping remove from the track before relamping.
- If you are unclear as to how to proceed, contact a qualified electrician.
- Minimum distance from the front of the lamp to combustible surfaces is 8".
- Make sure all connections are tight.
- Dimming halogen lamps greatly reduces lamp life.
- Turn off and allow to cool before replacing lamp.
- Lamp gets HOT quickly! Contact switch only when turning on.
- Do not touch hot lens, guard, or enclosure.
- Keep lamp away from materials that may burn.
- Do not touch the lamp at any time. Use a soft cloth. Oil from skin may damage lamp.
- Do not operate the luminaire fitting with a missing or damaged shield.
- Save these instructions.


NOTE: This pendant can be hung either from a Transitions Series rail (not supplied) or from the supplied canopy. Follow the instructions for the appropriate mounting method.

ASSEMBLING PENDANT/SHORTENING PENDANT

1. Determine length of pendant and shorten cable from the splice compartment (C). Be sure to add 5" for electrical connections when installing as a mono-point.
2. Unthread top of splice compartment (C). Set top of splice compartment (C) and strain relief collar at new location. NOTE Strain relief collar is threaded and should be threaded up and down cable. Be sure 1/4" of cable jacket is protruding out of strain relief collar. Secure in place by tightening the two set screws.
3. Place glass support (F) at desired height on stem (O) and secure by tightening set screw with supplied allen wrench. Place shade (A) on top of glass support (F) so it hangs evenly. Place hood (G) on top of shade (A).
4. Make connections between socket leads and pendant cable using wire nuts inside the splice compartment (C) – Black to Black/White to White/Ground to Ground. Make sure no wires are left exposed and carefully tuck wire nuts into bottom half of splice compartment (C).
5. Close splice compartment (C) by threading the two halves together.



GROUNDING AND MOUNTING BAR LOCK UP FOR OPTIONAL MONO-POINT CANOPY



1. Remove rail adapter (E) by cutting wire below rail adapter (E). Carefully strip outer jacket so wires are exposed to make wire connections.
2. Slide collar (L), canopy (K), and hex nut and lock washer (B), mounting bar (J), and nipple (V) over wire to top of splice compartment (C).
3. Install strain relief (O). Tighten strain relief set screw with a flat head screw driver.
4. Secure mounting bar (J) to outlet box using outlet box screws (not supplied).
5. Make electrical connections with UL listed connectors such as wire nuts.
 - a. House Black to Fixture Black
 - b. House White to Fixture White

Take house ground wire and fixture ground wire and wrap around the green grounding screw located on the mounting bar (J). Secure by tightening the green grounding screw. Make sure no wires are left exposed and tuck wires into outlet box.
6. Raise canopy (K) against ceiling and thread collar (L) to the nipple (V).

FIXTURE INSTALLATION

CORRECT





FIGURE 3

INCORRECT



ATTACH PENDANT TO RAIL – REFER TO FIGURE 3

1. Unthread cap (R) from rail adapter (E).
2. Making sure contacts (P) will align with conductors (Q) on rail, set the bottom of rail adapter (E) to the bottom of the rail and “roll” rail adapter (E) up onto the rail.
3. Close the hinged door of rail adapter (E) over the rail and secure fixture to rail by threading cap (R) back onto rail adapter (E).
4. Use supplied allen wrench to tighten strain relief set screws (D).